



**NOTES**

1. DOGHOUSE OPENING MAY ONLY BE USED WHEN PLACING A NEW MANHOLE OVER AN EXISTING LINE; OTHERWISE, THE OPENING MUST BE CAST. SIZE, LOCATION AND ANGLE OF ENTRY SHOULD BE AS REQUIRED BY THE PLANS.
2. OPENINGS IN PRECAST UNITS ARE TO BE 4" MINIMUM TO 8" MAXIMUM LARGER THAN THE OUTSIDE DIAMETER OF THE PROPOSED PIPE.
3. INVERT SHAPING TO CONFORM TO FIGURE 300.07.

NOT TO SCALE

INDIANAPOLIS DEPARTMENT OF PUBLIC WORKS  
 SANITARY SEWER DOGHOUSE MANHOLE

FIGURE 300.06