



MINIMUM BEDDING, HAUNCHING, AND INITIAL BACKFILL DEPTHS		
PIPE SIZE	BEDDING (BELOW PIPE BARREL)	HAUNCHING AND INITIAL BACKFILL (ABOVE TOP OF PIPE)
24" & GREATER	8" MIN.	1/2 OD. MIN.

MINIMUM TRENCH WIDTHS	
PIPE SIZE	MINIMUM WIDTH
24" AND GREATER	(O.D. X 1.25) + 12"

NOT TO SCALE

INDIANAPOLIS DEPARTMENT OF PUBLIC WORKS  
RIGID PIPE BEDDING & BACKFILL REQUIREMENTS

FIGURE 400.03